



BUILDING B - ROOF PLAN
SCALE: 1/8" = 1'-0"



- NOTES:**
1. PROVIDE INSULATION ROOF SADDLES AT HIGH SIDE OF ALL ROOF OPENING CURBS AND AS REQUIRED AT OTHER LOCATIONS TO MAINTAIN A MINIMUM OF 1/4" PER 12" ROOF SLOPE. ROOF SADDLES ARE ONLY INDICATION FOR LOCATION NOT ACTUAL SIZE. MINIMUM SLOPE TO BE 1/4" PER 12" WITH 1/8" PER 12" IN VALLEYS.
 2. VERIFY SIZE & LOCATION OF MECHANICAL UNITS OPENINGS WITH MECHANICAL CONTRACTOR.
 3. T.O.P. = TOP OF PARAPET
T.O.S. = TOP OF STEEL (UNDERLIES) OF METAL DECK
R.D. = ROOF DRAIN - SEE DETAIL (2) (A3.2)
O.F. = OVERFLOW DRAIN - SEE DETAIL (2) (A3.3)
 4. PROVIDE WALKWAY PADS FROM ROOF HATCH TO ALL ROOF TOP UNITS AND AROUND PERIMETER OF EACH UNIT- SEE SPEC.

INSERT THESE NOTES IN YOUR DRAWING

